

TROUBLESHOOTING AFTER FAILED TEST

This guide will help you with troubleshooting if the test performed to ensure that systems performance fails.

01. SYSTEM DELIVERS LESS POWER THAN EXPECTED

The test result can be seen in the Site Status, the Logbook in the Control Panel and in the power graph in EnergyInBalance. The test is performed at 11.40 pm. In the test below, the system has delivered 50.5% of 20 kW when discharging and 50.0% when charging.

Site Status

FAIL TEST

1 dag

50,5% / 3,9% / 50,0 %

Testing tonight

Logbook

[FCR-D FAIL ACTIVATION] 1x epost@epost.com --18511-- 50,5/3,9/50,0 % (20kW)

EnergyInBalance



The test can be seen in the power graph in EnergyInBalance. The graph above shows that only 9.89 kW was delivered out of 20 kW.

System delivers less power than expected

Are there any import/export limitations present in inverter settings that can limit the power?

Is the system correctly registered?
See Registration info or
#BEGIN_BATTERY_REGISTRATION in logbook

Some batteries limit power due to temperature.

Perform an “internal” manual test on the inverter. This means disconnecting the communication between CM10 and inverter, and testing max charge/discharge.
Are you able to get desired power?

If you want CheckWatt to lower the power in order to pass the test, message your contact person the XX kW you want it to be tested on.

02. TEST RESULTAT IS INF%

If test resultat is **INF%**, we do not have connection to the system.

Site Status

FAIL TEST

1 dag

INF % / 0.0% / INF %

Testing tonight

Logbook

[FCR-D FAIL ACTIVATION] 1x epost@epost.com --18511-- INF/0,0/INF % (20 kW)

Test resultat is INF%

Make sure internet connection is stable

Make sure CM10 has connection to inverter

If CM10 does not have connection to inverter, go to the document
Troubleshooting Installation